



# Halifax

## RFT# 4240 - Addendum #3 Boiler Replacement, Bicentennial School

To: All Bidders  
Date: May 30, 2024  
From: Nancy Rideout, Purchasing Manager  
Office: (902) 464-2000 ext. 2222  
Email: [nrideout@hrce.ca](mailto:nrideout@hrce.ca)

---

**The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:**

### **Question #1**

With reference to section 23 52 00 Condensing boilers:

Vendor requests that Thermal Solutions model AMP-2000 be approved as an alternate.

### **Response**

Thermal Solutions model AMP-2000 is not acceptable.

The specification is for a fire tube boiler - the AMP-2000 is a water tube boiler.

### **RFT 4240 - End of Addendum #3**

---

---

***PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:***

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name