



Halifax
Regional Centre for Education

RFQ # 4256 - Addendum # 2 Re Lamp Project - Multiple Schools

To: All Bidders
Date: November 13, 2024
From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

*The closing date for this RFQ is extended to Monday, November 18 – 2pm (ATL)
No further questions are accepted for this competition.*

Ballast Compatibility for RFQ Specifications and Alternate Products

1. TLED Lamp Ballast Compatibility

All bidders will submit ballast compatibility list for their proposed product with their bid. Please note two common ballasts found at the proposed schools are listed below.

- GE Ultra Max T8 – GE232MAX-L/ULTRA – 120-277 volts
- Osram-Sylvania – QHE2X32T8/UNV ISL-SC – 120-277 volts

2. RENO Lamp – Suitable Replacement

From reviewing ballast compatibility list provided, it appears that the RENO lamp is not compatible with GE Ultra Max T8 – GE232MAX-L/ULTRA – 120-277 volts.

End of Addendum # 2 – RFQ# 4256

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

Signature

Company Name